



5761 Keyo Building
Orono, ME 04469-5761

Main:207-581-2712
IDD/TDY:207-973-3262
www.maine.edu

REQUEST FOR PROPOSALS #030-17
University of Maine at Presque Isle Scheduled Testing, Inspection &
Cleaning of Life Safety Systems Services
RESPONSE ADDENDUM #3
September 22, 2016

This addendum responds to initial questions submitted by vendors.

The University of Maine

University of Maine
at Augusta

University of Maine
at Farmington

University of Maine
at Fort Kent

University of Maine
at Machias

University of Maine
at Presque Isle

University of
Southern Maine

Q1. Can the University provide the size of the kitchen hoods, exhaust fan and duct length for pricing of semi-annual cleaning under Exhibit 2, Schedule II?

A1. *The **Main Kitchen Hood** is 8.5 feet x 17 feet / Exhaust Fan 36 inches / Duct Length 6 feet; **Serving Line Hood** is 2.5 feet x 12 feet / Exhaust Fan 24 inches / Duct Length 6 feet; **Owls Nest Hood** is 2 feet x 5.5 feet / Exhaust Fan 20 inches / Duct Length 6 feet*

Ryan Ward
Sourcing Manager
Strategic Procurement
University of Maine Services
5761 Keyo Building
Orono, ME 04469-5761

